

ADDENDUM NO.1

CONTRACTTITLE:

FOR THE SUPPLY AND DELIVERY OF ELECTRICAL CABLES AND CONDUCTORS TO MOGALE CITY MUNICIPAL STORES AT CHAMDOR ON AN AS AND WHEN REQUIRED BASIS FOR A PERIOD OF THREE (3) YEARS.

TENDERNUMBER:

IDS (E) 03/2025

RE: ENQUIRY, INFORMATION REGARDING THE SUPPLY AND DELIVERY OF ELECTRICAL CABLES AND CONDUCTORS, TENDER NUMBER - IDS (E) 03/2025

With reference to the enquiry that was received regarding the supply and delivery of electrical conductors / cables, the information is as follows:

1. The information regarding which Table cable is required is on the first page of the specifications under Point No 1 the third bullet which indicates that it must be Table 18.
2. The conductor type that is required for the PILCDSTA and XLPE must be copper for all the 3 core conductors.